

Craig Burne

From: Kim Tifflin-Sing <Kim.Sing@durban.gov.za>
Sent: Wednesday, 18 October 2023 12:00
To: Fisiwe Sishi
Subject: RE: UPGRADE OF AMAOTI NO3 SECONDARY SCHOOL WATER PROPOSAL

Gooday,

Kindly be advised that application F231011/978 is with the Technician.

Regards
Kim T-S

From: Fisiwe Sishi <fisiwe.sishi@nakogroup.com>
Sent: Wednesday, October 18, 2023 11:42 AM
To: Waterplanning App <Waterplanning.App@durban.gov.za>
Cc: Zabathwa Mzamane <Zabathwa.Mzamane@durban.gov.za>
Subject: Re: UPGRADE OF AMAOTI NO3 SECONDARY SCHOOL WATER PROPOSAL

You don't often get email from fisiwe.sishi@nakogroup.com. [Learn why this is important](#)



Good Morning Waterplanning,

This email serves as a follow-up on the email below.

Warm Regards,
Fisiwe



Fisiwe Sishi

ILISO Consulting (Pty) Ltd t/a NAKO ILISO
ILISO Building, Derby Downs Office Park, 11 Derby Place, Westville, Durban, 3630
PO Box 686, Gillits, 3603
T: +27 (0) 87 225 0900 **E:** fisiwe.sishi@nakogroup.com
<https://iliso.com>
Level 1 BBBEE Contributor | ISO 9001:2015 Certified

From: Fisiwe Sishi <fisiwe.sishi@iliso.com>
Sent: Tuesday, October 10, 2023 1:45 PM
To: Waterplanning App <Waterplanning.App@durban.gov.za>
Cc: Zabathwa Mzamane <zabathwa.mzamane@durban.gov.za>
Subject: Re: UPGRADE OF AMAOTI NO3 SECONDARY SCHOOL WATER PROPOSAL

Good Day

Kindly find the attached revised report.

Thank you,
Fisiwe

From: Zabathwa Mzamane <Zabathwa.Mzamane@durban.gov.za>
Sent: Tuesday, October 10, 2023 8:34 AM
To: Fisiwe Sishi <fisiwe.sishi@iliso.com>
Subject: RE: UPGRADE OF AMAOTI NO3 SECONDARY SCHOOL WATER PROPOSAL

Hi,

Not yet, I think it's also because I was on sick leave.
Please email an electronic copy to Waterplanning App Waterplanning.App@durban.gov.za and copy me.

Please note that I prefer electronic as it makes it easier to keep track.

Regards
ZM

From: Fisiwe Sishi <fisiwe.sishi@nakogroup.com>
Sent: Thursday, 05 October 2023 4:13 PM
To: Zabathwa Mzamane <Zabathwa.Mzamane@durban.gov.za>
Subject: Re: UPGRADE OF AMAOTI NO3 SECONDARY SCHOOL WATER PROPOSAL

Good day Zabathwa,

Kindly confirm if you have received the Amaoti No3 Report from our office, which was delivered this afternoon at your offices.

Warm Regards,
Fisiwe

Fisiwe Sishi

ILISO Consulting (Pty) Ltd t/a NAKO ILISO

ILISO Building, Derby Downs Office Park, 11 Derby Place, Westville, Durban, 3630
PO Box 686, Gillits, 3603

T: +27 (0) 87 225 0900 E: fisiwe.sishi@nakogroup.com

<https://iliso.com>

Level 1 BBBEE Contributor | ISO 9001:2015 Certified

From: Zabathwa Mzamane <Zabathwa.Mzamane@durban.gov.za>

Sent: Wednesday, September 27, 2023 12:10 PM

To: Fisiwe Sishi <fisiwe.sishi@iliso.com>

Subject: RE: UPGRADE OF AMAOTI NO3 SECONDARY SCHOOL WATER PROPOSAL

Good day Fisiwe,

We have reviewed your preliminary design report and below is the feedback.

Your report dated August 2023, titled "*Amaoti No.3 Secondary School Durban, Detailed Design Report Water Infrastructure - Revision 0: 1900016*", has reference.

- It is noted that Amaoti No.3 Secondary School is located in Brookdale, Phoenix and will accommodate 1200 students and 25 staff members with an estimated water demand of 153 125 litres/day. The site currently comprises of temporary prefab structures and containerized ablutions a greenfield site with an existing sports field.
- Your report is titled 'Detailed Design', please note that the Planning department only reviews preliminary design. The detailed designed must be submitted to the Design branch once the prelim design has been approved, please amend the title accordingly.
- The proposed school falls under Phoenix 4 reservoir supply zone and not the Ntuzuma 5 reservoir stated in your report, please review accordingly.
- The required watermain upgrade will be the responsibility of the developer with the related costs.
- All designs for any proposed municipal water infrastructure to supply this development should be submitted to EWS Planning and Design branch for checking and approval timeously, in line with the attached Standard Operation Procedure.

Should you have any queries, please feel free to contact this Unit.

Regards
Zabathwa

From: Fisiwe Sishi <fisiwe.sishi@nakogroup.com>
Sent: Monday, 21 August 2023 3:11 PM
To: Waterplanning App <Waterplanning.App@durban.gov.za>; Zabathwa Mzamane <Zabathwa.Mzamane@durban.gov.za>
Cc: Derrick Ngidi <derrick.ngidi@iliso.com>
Subject: UPGRADE OF AMAOTI NO3 SECONDARY SCHOOL WATER PROPOSAL

You don't often get email from fisiwe.sishi@nakogroup.com. [Learn why this is important](#)

Dear Sir/Madam

I trust this email finds you well.

We have been appointed by COEGA development corporation to provide civil engineering professional services for the design and construction of the school upgrade of Amaoti Secondary School, which is located in Brookdale, Phoenix and therefore propose to obtain water supply to the upgraded School from the Phoenix 4 reservoir.

Please find the attached report for your review, comments and approvals.

Kind regards,

Fisiwe

Fisiwe Sishi

ILISO Consulting (Pty) Ltd t/a NAKO ILISO

ILISO Building, Derby Downs Office Park, 11 Derby Place, Westville, Durban, 3630
PO Box 686, Gillits, 3603

T: +27 (0) 87 225 0900 **E:** fisiwe.sishi@nakogroup.com
<https://iliso.com>

Level 1 BBBEE Contributor | ISO 9001:2015 Certified